SPECIFICATION SUBMITTAL

| Project: | |
|----------------------------|--|
| Architect/Engineer:_ | |
| Builder/Developer: | |
| Plumbing Contractor | |





FOR PEX, COPPER & CPVC



One Valve Fits ALL



P05-XF





7/8" Ballo







1/4" Com



3/8" Com Adapter (w/o nut





3/8" x 3/4" Whirlpool Elbow

FlowTite® 4ALL® White Supply Stop Valve / Factory Attached One-Piece Flexible Reinforced PVC Connector System - For Copper. CPVC and PEX Pipe

| - y | соррон, ст. то шиш т =лет фо |
|------------|------------------------------|
| | |
| | |

| Model Number | Description |
|----------------------------|---|
| □ P05-3,2 (XF-XC) | Valve-Only: 1/2" Nominal Supply Stop Valves With 3/8" or 1/4" O.D. Compression Nut. |
| P05LP-5,3 (XP-XF-XC-XL-XE) | One-Piece: Factory Attached Flexible PVC connector for Faucets and Dishwashers. |
| □ P05CP-7 (XF) | One-Piece: Factory Attached Flexible PVC connector for Toilets. |
| □ P05IP-2 (F-T) | One-Piece: Factory Attached Flexible PVC connector for Ice Makers. |

Design Features / Benefits

| 10 year limited warranty including labor and material for residential and one year for commercial. | Property owner protection.Reduced maintenance costs. |
|---|--|
| Tested to 1,000 psi. | > 10:1 margin of safety. |
| Over 35 million <i>PUSHON</i> technology valve installations in over 2.5 million new U.S. homes since 1988. | Long-term proven technology performance. |
| Easy Pull/Push ON/OFF Handle. | No sticking or leaking turn handles due to dried out rubber packing. |
| Original one-piece factory attached connector. | Reduced maintenance costs.Eliminates potential leaks at joints. |
| 100% non-metallic water contact. | No lead, no internal corrosion, no brass dezincification. |
| NSF certified. | Health Safe. |
| Clean look. | > To fit any interior. |
| Removable and Reusable. | Installation does not damage pipe. |

Listings:

NSF/ANSI 61 IAPMO File 2657 (cUPC/IPC/NPC of Canada) IAPMO File 6518 (Lead Free)

Manufactured in accordance with:

NSF/ANSI 61 Section 9 Certified ASME A112.18.1/CSA B125.1 Section 1417(d) US SDWA and NSF/ANSI 372

