369987k 1 01.25.23

Caséta Load Controls

The Caséta family of dimmers, switches, and fan controls can be controlled directly and remotely when paired with Pico remote controls providing a system that delivers convenience and ease of installation.

Caséta dimmers, switches, and fan controls use Lutron patented Clear Connect RF Technology which enables wireless communication with Pico remote controls, Caséta motion sensors, and the Lutron Smart Hub and Smart Hub PRO (formerly Smart Bridge and Smart Bridge PRO).

Features

- Works with Pico remote control
- Works with Caséta motion sensor
- Works with the Lutron App (via a Smart Hub or Smart Hub PRO)1
- Lutron patented Clear Connect RF Technology works through walls and floors
- Includes Front Accessible Service Switch (FASS) for safe lamp replacement
- Works with Lutron Radio Powr Savr occupancy and vacancy sensors in standalone applications (sensors do not work with Smart Hub or Smart Hub PRO)




Figure 1: Original Smart Switches




Figure 2: Original Smart Dimmers




Figure 3: Original ELV+ Smart Dimmers




Figure 4: Caséta Plug-In Lamp Dimmers




Figure 5: Original Smart Fan Controls



Figure 6: Diva **Smart Dimmers**



Figure 7: Claro **Smart Switches**



Figure 8: Claro Smart Accessory Switches

Page

LUTRON SPECIFICATION SUBMITTAL

The Lutron App is required for setup and usage with the Smart Hub and Smart Hub PRO. The Lutron App is compatible with iOS₃ devices version 8.0 or later and Android™ devices 4.0 or later.

Note: Certain models or load types will require a neutral connection

(see Load Type and Capacity sections).

Job Name:	Model Numbers:
Job Number:	

369987k 2 01.25.23

Specifications

Regulatory Approvals

- cULus Listed
- NOM Certified
- FCC Approved. Complies with the limits for a Class B digital device, pursuant to Part 15 of the FCC Rules
- Industry Canada Certified
- IFTEL Certified
- NEMA 410: PD (-5ANS, -6ANS, -5WS, -10NXD, -5NE), DVRF (-6L, -5NS)

Power

Operating voltage:

- 120 V~ 50/60 Hz: PD (-3PCL, -6WCL, -10NXD, -6ANS, -5ANS, -5NE, -FSQN), DVRF (-6L, -5NS, -AS)
- 120/277 V∼ 50/60 Hz: -5WS-DV

Key Design Features

- Tested to withstand electrostatic discharge without damage or memory loss, in accordance with IEC 61000-4-2.
- Tested to withstand surge voltages without damage or loss of operation, in accordance with IEEE C62.41-1991 Recommended Practice on Surge Voltages in Low-Voltage AC Power Circuits.
- Load controls always operate locally and do not require system control.
- Power failure memory: should power be interrupted, the control will return to its previously set level prior to the interruption when power is restored.
- PD-5WS-DV, PD-5ANS, PD-6ANS, PD-10NXD, DVRF-5NS, and DVRF-6L use conventional 3-way wiring.
- DVRF-6L and DVRF-5NS can also be wired with an accessory switch, DVRF-AS.
- Uses Lutron Claro wallplates or designer-style wallplates from other manufacturers. Wallplates are sold separately.
- Lutron Claro wallplates snap on with no visible means of attachment.
- Requires a 1-gang U.S. wallbox. 3½ in (89 mm) depth recommended, 2¼ in (57 mm) depth minimum¹.

STITEON SPECIFICATION SUBMITTAL

¹ PD-FSQN requires 2½ in (63½ mm) minimum depth.

Key Design Features (continued)

- PD- models use green status LED(s) to indicate load status.
- DVRF-6L uses a white soft glow light bar and the DVRF-5NS uses a white status LED to indicate load status.
- PD-FSQN provides 4 quiet fan speeds plus OFF for a single ceiling fan.

System Communications and Capacity

- Caséta switches, dimmers, and fan controls communicate with Pico remote controls, Caséta motion sensors, and the Lutron Smart Hub/Smart Hub PRO through Radio Frequency (RF).
- The Caséta switches, dimmers, and fan controls must be located within 60 ft (18 m) line-of-sight or 30 ft (9 m) through walls of a Lutron Smart Hub, Smart Hub PRO, or Caséta Repeater.
- The Caséta switches, dimmers, and fan controls must be located within 60 ft (18 m) line-of-sight or 30 ft (9 m) through walls of Pico remote controls or Caséta motion sensors (with no Smart Hub installed).

Device limits

- Pico remote controls and Caséta motion sensors: up to 10 devices (total) may be paired to each Caséta switch/dimmer (with no Smart Hub installed).
- Smart Hub or Smart Hub PRO system: up to 75 total wireless devices (Caséta dimmers/switches, Pico remote controls, Caséta motion sensors, and shades) are supported per system. Smart Hub or Smart Hub PRO counts as one device. The Caséta repeater counts as one device.

Environment

- Ambient operating temperature: 32 °F to 104 °F (0 °C to 40 °C), 0% to 90% humidity, non-condensing. Indoor use only.
- PD-5WS-DV, PD-5ANS, PD-6ANS, PD-10NXD, DVRF-5NS, and DVRF-6L can be used with a mechanical switch in 3-way applications.

Dago

**LOTTON OF LOT	TOATION GODWITTAL	1 agc
Job Name:	Model Numbers:	
Job Number:		

369987k 3 01.25.23

Features

Original Smart Models	2-wire Switch PD-5WS-DV	Neutral Switch PD-5ANS, PD-6ANS	Dimmer PD-6WCL	PRO Dimmer PD-10NXD	ELV+ Dimmer PD-5NE	Plug-In Dimmer PD-3PCL	Fan Control PD-FSQN
Figure # (from page 1)	1	1	2	2	3	4	5
Simple two-wire installation (no neutral wire required)	V		√	√1			
Capable of dimming loads			√	√	√	V	
Preset (user defined favorite level)					√		√
Works with Hi-lume 1% 2-Wire LED Drivers (forward-phase only)	V	V	V	V	V		
Works with Power Interfaces (PHPM and GRX-TVI)				√	√		
Works with Power Interfaces (PHPM-SW)		V					
No wiring required						V	
Controls speed of a single ceiling fan							√

Diva and Claro Smart Models	Diva Smart Dimmer DVRF-6L	Claro Smart Switch DVRF-5NS	Claro Smart Accessory Switch DVRF-AS
Figure # (from page 1)	6	7	8
Simple two-wire installation (no neutral wire required)	V		V
Capable of dimming loads	√		
Preset (user defined favorite level)	V		
Works with Hi-lume 1% 2-Wire LED Drivers (forward-phase only)	V	V	
Works with Power Interfaces (PHPM-SW)		√	

Job Name:	Model Numbers:
Job Number:	

 $^{^{\}rm 1}$ $\,$ In some low-wattage applications the PD-10NXD will require a neutral wire connection.

369987k 4 01.25.23

Load Type and Capacity - Switches and Fan Control

Model Number	Description	Voltago	Load Type	Minimum	Maximum Load ³			
woder number	Description	Voltage	Load Type	Load	Not Ganged	End of Gang	Middle of Gang	
		120 V~	Incandescent/ Halogen	25 W	600 W	450 W	350 W	
		277 V~	Incandescent/ Halogen	25 W	1350 W	1100 W	800 W	
		120 V~	MLV	25 W	600 VA/475 W	450 VA/350 W	350 VA/275 W	
DD 51410 D) d	Two-wire	277 V∼	MLV	25 W	1350 VA/1075 W	1100 VA/875 W	800 VA/625 W	
PD-5WS-DV ¹	switch	120 V~	General Purpose Fan	0.4 A	3 A	3 A	3 A	
		120/277 V∼	LED	Use LUT-MLC ²	5 A	4 A	3 A	
		120/277 V∼	Fluorescent	Use LUT-MLC ²	5 A	4 A	3 A	
		120 V∼	ELV	Use LUT-MLC ²	600 W	450 W	350 W	
		277 V∼	ELV	Use LUT-MLC ²	1350 W	1100 W	800 W	
Neur		120 V~	Incandescent/ Halogen	10 W	600 W	600 W	600 W	
	Neutral-wire		MLV	10 W	600 VA	600 VA	600 VA	
PD-5ANS	switch		Fan	0.1 A	3 A	3 A	3 A	
DVRF-5NS (neutral connection required)			LED	1 bulb	5 A	5 A	5 A	
			Fluorescent	1 ballast	5 A	5 A	5 A	
			ELV	10 W	600 W	600 W	600 W	
			PHPM-SW	1 interface	2 interfaces	2 interfaces	2 interfaces	
			Incandescent/ Halogen	10 W	720 W	720 W	600 W	
	Neutral-wire	120 V∼	MLV	10 W	720 VA	720 VA	600 VA	
PD-6ANS	switch		Fan	0.1 A	3.6 A	3.6 A	3.6 A	
PD-6ANS-XX-C	(neutral connection		LED	1 bulb	6 A	6 A	5 A	
	required)		Fluorescent	1 ballast	6 A	6 A	5 A	
			ELV	10 W	720 W	720 W	600 W	
			PHPM-SW	1 interface	3 interfaces	3 interfaces	3 interfaces	
PD-FSQN ⁴	Fan speed control (neutral connection required)	120 V~	Single Ceiling Fan (permanent split-capacitor motor)	0.1 A	1.5 A	1.5 A	1.5 A	

No neutral wire required.

LUTRON SPECIFICATION SUBMITTAL

Job Name:	Model Numbers:
Job Number:	

To ensure proper operation of the switch with LED, fluorescent, and ELV loads, a LUT-MLC (included) may be required, especially at lower wattages. If the status LED on the switch is flashing or solid red in color, a LUT-MLC must be installed. To guarantee best performance, installing a LUT-MLC with these load types regardless of wattage is recommended. Rarely, some load types may still flicker or glow in the off state even with the LUT-MLC installed, in which case a different load may be required or more than one LUT-MLC is required.

³ See "Ganging and Derating" section.

Not for use with fans that have integrated fan speed and/or light control modules, DC motor fans, fans with remote controls, bathroom or kitchen exhaust type fans.

369987k 5 01.25.23

Load Type and Capacity - Dimmers

Model Number Description Voltage		Valtage	Lood Type	Minimum	Maximum Load		
Model Number	Description	Voltage	Load Type	Load	Not Ganged	End of Gang	Middle of Gang
			Incandescent/Halogen	10 W with neutral (25 W without neutral)	1000 W	800 W	600 W
			MLV Halogen	10 W	1000 VA	800 VA	600 VA
	Dimmer PRO (neutral		MLV LED	See Application N	lote #559		
PD-10NXD PD-10NXD-XX-C ⁸	connection required for	120 V~	LED (120 V~ Rated) ³	1 bulb ³	250 W	250 W	250 W
101000	certain load		Hi-lume 1% 2-Wire LED drivers	1 driver	13 drivers	13 drivers	13 drivers
	typoo,		Dimmable Ballasts ⁵	1 ballast	1000 VA	800 VA	600 VA
			PHPM-PA/3F and GRX-TVI ⁴	1 interface	3 interfaces	3 interfaces	3 interfaces
PD-3PCL ^{1, 9} Plug-in Lamp PD-3PCL-WH-C ^{1, 8, 9} Dimmer			Incandescent/Halogen	10 W	300 W	N/A	N/A
	120 V~	LED (120 V∼ Rated) ³	1 bulb ³	100 W	N/A	N/A	
	Phase Selectable Dimmer (neutral		Incandescent/Halogen	10 W	500 W	400 W	300 W
			LED (120 V~ Rated) ^{3, 6, 7}	1 bulb ³	250 W	250 W	250 W
			MLV Halogen ^{2, 6, 7}	10 W	400 VA	400 VA	400 VA
		120 V~	ELV Halogen	10 W	500 W	400 W	300 W
PD-5NE PD-5NE-XX-C ⁸			Hi-lume 1% 2-Wire LED drivers ^{6, 7}	1 driver	20 drivers	20 drivers	20 drivers
	connection		Dimmable Ballasts ^{5, 6, 7}	1 ballast	400 VA	400 VA	400 VA
	required)		PHPM-PA/3F and GRX-TVI ^{6, 7}	1 interface	3 interfaces	3 interfaces	3 interfaces
			ELV LED	See Application N	See Application Note #559		
			MLV LED ^{6, 7}	See Application Note #559			
			Incandescent/Halogen	25 W	600 W	500 W	400 W
PD-6WCL PD-6WCL-XX-C ⁸ DVRF-6L	Dimmer	120 V~	LED (120 V∼ Rated) ³	1 bulb ³	150 W	150 W	150 W

¹ Cannot be ganged.

- ⁸ Canadian packaged product.
- 9 Available in WH only.

\$LUTRON SPECIFICATION SUBMITTA

Job Name:	Model Numbers:
Job Number:	

Need to change load type to MLV. See www.casetawireless.com/change_phase

³ See bulb list at www.lutron.com/led

⁴ For PD-10NXD, a neutral connection is required for MLV loads, LED drivers, dimmable ballasts, and power modules (PHPM-PA, PHPM-3F, and GRX-TVI).

⁵ Compatible dimmable ballasts include Tu-Wire, Mark 10_o, and PowerSense_o.

These loads are best operated using a forward-phase control. Consult https://www.casetawireless.com/support to ensure the appropriate phase for bulb models used.


SSL7 compliant when in forward-phase.

369987k 6 01.25.23

Ganging and Derating


When ganging with other switches/dimmers in the same wallbox, derating is required. See "Load Type and Capacity" charts.


Original Smart Models




Note: Fin removal is not required for PD-5WS-DV, as it ships without fins.

Diva and Claro Smart Models







Note: DVRF- models don't have fins but derating may still be required. See "Load Type and Capacity" charts.


LUTRON SPECIFICATION SUBMITTAL


Job Name:	Model Numbers:
Job Number:	

369987k 7 01.25.23

Operation


Original Smart Models






FASS - Front Accessible Service Switch

Important Notice: To service load, remove power by pulling out the FASS as far as possible. To restore power after servicing load, push the FASS back in completely.






LUTRON SPECIFICATION SUBMITTAL


Job Name:	Model Numbers:
Job Number:	

369987k 8 01.25.23

Operation (continued)

Diva and Claro Smart Models






FASS - Front Accessible Service Switch

Important Notice: To service load, remove power by pulling out the FASS as far as possible.

To restore power after servicing load, push the FASS back in completely.





LUTRON SPECIFICATION SUBMITTAL

Job Name:	Model Numbers:
Job Number:	

369987k 9 01.25.23

Mounting





Note: Fin removal is not required for PD-5WS, DVRF-6L, DVRF-5NS, and DVRF-AS. They all ship without fins.


LUTRON SPECIFICATION SUBMITTAL

Job Name:	Model Numbers:
Job Number:	


369987k 10 01.25.23

Dimensions

Original Smart Models



Plug-In Dimmer




LUTRON SPECIFICATION SUBMITTAL

Job Name:	Model Numbers:
Job Number:	


369987k 11 01.25.23

Dimensions (continued)

Diva and Claro Smart Models



Accessory Switch



\$LUTRON SPECIFICATION SUBMITTAL


Page Job Name: Model Numbers: Job Number:


Job Number: Page Model Numbers:

369987k 13 01.25.23

Wiring Diagrams - Switches

Single Pole Installation (load is controlled from 1 location)





LUTRON SPECIFICATION SUBMITTAL

(continued on next page...)

AND INTEREST OF LOTH OF MAINTING		. 490
Job Name:	Model Numbers:	
Job Number:		

¹ When using controls without a mechanical 3-way switch, cap the blue terminal. **Do not** connect the blue wire to any other wiring or to ground.

² A LUT-MLC ensures proper function when LED, fluorescent, or ELV loads are used. Install the LUT-MLC inside a load fixture or in a separate junction box within the circuit.


³ The red wire must be connected to the load and the black wire must be connected to Line/Hot. The switch will not work if the wires are reversed.

369987k 14 01.25.23


Wiring Diagrams - Switches (continued)

3-Way Installation (load is controlled from 2 locations)

Option 1: With mechanical switch



PD-5WS-DV (Line-side)



(continued on next page...)

LUTRON SPECIFICATION SUBMITTAL

Job Name:	Model Numbers:
Job Number:	

Location of Caséta switch and mechanical switch may be reversed.


A LUT-MLC ensures proper function when LED, fluorescent, or ELV loads are used. Install the LUT-MLC inside a load fixture or in a separate junction box within the circuit.

369987k 15 01.25.23


Wiring Diagrams - Switches (continued)

3-Way Installation (load is controlled from 2 locations) (continued)

Option 1: With mechanical switch (continued)



PD-5ANS, PD-6ANS, DVRF-5NS (Line-side)



Location of Caséta switch and mechanical switch may be reversed.

² The red wire must be connected to the load and the black wire must be connected to Line/Hot. The switch will not work if the wires are reversed.


369987k 16 01.25.23

Wiring Diagrams - Switches (continued)


3-Way Installation (load is controlled from 2 locations) (continued)

Option 2: With Pico remote controls

PJ2-2B-xx and wallbox mounting adapters (PICO-WBX-ADAPT)



PD-5ANS, PD-6ANS, DVRF-5NS



- When using controls without mechanical 3-way switch, cap the blue terminal. **Do not** connect the blue wire to any other wiring or to ground.
- A LUT-MLC ensures proper function when LED, fluorescent, or ELV loads are used. Install the LUT-MLC inside a load fixture or in a separate junction box within the circuit.
- The mechanical switch will need to be removed so the Pico remote control can be installed.
- The red wire must be connected to the load and the black wire must be connected to Line/Hot. The switch will not work if the wires are reversed.

(continued on next page...)

LUTRON SPECIFICATION SUBMITTAL

Job Name:	Model Numbers:
Job Number:	

369987k 17 01.25.23


Wiring Diagrams - Switches (continued)

3-Way Installation (load is controlled from 2 locations) (continued)


Option 3: With an accessory switch

DVRF-5NS and Smart Accessory Switch (DVRF-AS)

DVRF-5NS (Line Side)



DVRF-5NS (Load Side)



Note: The Black wire of the main switch must always be connected to the Line/Hot wire. The Black and Red wires of the accessory switch are reversible.

LUTRON SPECIFICATION SUBMITTAL

Job Name:	Model Numbers:
Job Number:	

369987k 18 01.25.23


Wiring Diagrams - Switches (continued)

Multi-location Installation (load is controlled from 3 or more locations)


Option 1: With Pico remote controls

PJ2-2B-xx and wallbox mounting adapters (PICO-WBX-ADAPT)

PD-5WS-DV



PD-5ANS, PD-6ANS, DVRF-5NS



- 1 When using controls without mechanical 3-way switch, cap the blue terminal. **Do not** connect the blue wire to any other wiring or to ground.
- 2 A LUT-MLC ensures proper function when LED, fluorescent, or ELV loads are used. Install the LUT-MLC inside a load fixture or in a separate junction box within the circuit.
- The mechanical switch will need to be removed so the Pico remote control can be installed.
- ⁴ The red wire must be connected to the load and the black wire must be connected to Line/Hot. The switch will not work if the wires are reversed.

LUTRON SPECIFICATION SUBMITTAL

Job Name:	Model Numbers:
Job Number:	

369987k 19 01.25.23


Wiring Diagrams - Switches (continued)

Multi-location Installation (load is controlled from 3 or more locations) (continued)


Option 2: With accessory switches

DVRF-5NS and Smart Accessory Switch (DVRF-AS)¹

DVRF-5NS (Line Side)




DVRF-5NS (Load Side)



DVRF-5NS (In the Middle)

Note: Main switch can go in any location.



Up to ten (10) accessory switches may be connected to the switch. Total blue wire connection wire length may be up to 150 ft (45 m).

Note: The Black wire of the main switch must always be connected to the Line/Hot wire. The Black and Red wires of the accessory switch are reversible.


LUTRON SPECIFICATION SUBMITTAL

Job Name:	Model Numbers:
Job Number:	


369987k 20 01.25.23


Wiring Diagrams - Dimmers

Single Pole Installation (load is controlled from 1 location)



PD-6WCL





LUTRON SPECIFICATION SUBMITTAL

Job Name:	Model Numbers:
Job Number:	

¹ When using controls without mechanical 3-way switch, cap the blue terminal. **Do not** connect the blue wire to any other wiring or to ground.

 $^{^{\}rm 2}$ Location of Caséta dimmer PRO and mechanical switch may be reversed.

³ For PD-10NXD only, neutral connection optional except for MLV loads, LED drivers, and power modules (PHPM-PA, PHPM-3F, and GRX-TVI).

⁴ For PD-5NE, neutral is required.


 $^{^{5}}$ Blue wire is only present on the PD-10NXD and DVRL-6L models.

369987k 21 01.25.23


Wiring Diagrams - Dimmers (continued)

3-Way Installation (load is controlled from 2 locations)

Option 1: With mechanical switch



PD-10NXD, PD-5NE (Line-side)



LUTRON SPECIFICATION SUBMITTAL


Job Name:	Model Numbers:
Job Number:	

369987k 22 01.25.23


Wiring Diagrams - Dimmers (continued)

3-Way Installation (load is controlled from 2 locations) (continued)

Option 1: With mechanical switch (continued)



DVRF-6L (Line-side)



LUTRON SPECIFICATION SUBMITTAL

Job Name:	Model Numbers:
Job Number:	

369987k 23 01.25.23


Wiring Diagrams - Dimmers (continued)

3-Way Installation (load is controlled from 2 locations) (continued)


Option 2: With Pico remote controls

PJ2-2B-xx and wallbox mounting adapters (PICO-WBX-ADAPT)

PD-10NXD, PD-5NE



DVRF-6L



- When using controls without mechanical 3-way switch, cap the blue terminal. **Do not** connect the blue wire to any other wiring or to ground.
- 2 A LUT-MLC ensures proper function when LED, fluorescent, or ELV loads are used. Install the LUT-MLC inside a load fixture or in a separate junction box within the circuit.
- The mechanical switch will need to be removed so the Pico remote control can be installed.
- ⁴ When using a Pico in a 3-way installation with a dimmer the Black and Red wires are reversible.

LUTRON SPECIFICATION SUBMITTAL

Job Name:	Model Numbers:
Job Number:	

369987k 24 01.25.23


Wiring Diagrams - Dimmers (continued)

3-Way Installation (load is controlled from 2 locations) (continued)


Option 3: With an accessory switch

DVRF-6L and Smart Accessory Switch (DVRF-AS)¹

DVRF-6L (Line Side)



DVRF-6L (Load Side)



LUTRON SPECIFICATION SUBMITTAL

Job Name:	Model Numbers:
Job Number:	

¹ When using an accessory switch in a 3-way installation with a dimmer, the Black and Red wires of both devices are reversible.

369987k 25 01.25.23


Wiring Diagrams - Dimmers (continued)

Multi-Location Installation (load is controlled from 3 or more locations)


Option 1: With Pico remote controls

PJ2-2B-xx and wallbox mounting adapters (PICO-WBX-ADAPT)

PD-10NXD or PD-5NE



PD-6WCL Black Black Travelers Travelers Pico Pico Line/Hot remote remote control 8 control & Dimmer Black wallbox wallbox mounting mounting adapter adapter 120 V~ 50/60 Hz Green Load Ground Neutral 0



- When using controls without mechanical 3-way switch, cap the blue terminal. **Do not** connect the blue wire to any other wiring or to ground.
- Location of Caséta dimmer PRO and mechanical switch may be reversed.
- For PD-10NXD only, neutral connection optional except for MLV loads, LED drivers, and power modules (PHPM-PA, PHPM-3F, and GRX-TVI).
- For PD-5NE, neutral is required.
- ⁵ Blue wire is only present on the PD-10NXD and DVRF-6L models.
- When using a Pico in a 3-way installation with a dimmer the Black and Red wires are reversible.

369987k 26 01.25.23


Wiring Diagrams - Dimmers (continued)

Multi-location Installation (load is controlled from 3 or more locations) (continued)


Option 2: With accessory switches

DVRF-6L and Smart Accessory Switches (DVRF-AS)^{1,2}

DVRF-6L (Line Side)




DVRF-6L (Load Side)



DVRF-6L (In the Middle)

Note: Main dimmer can go in any location.



- Up to ten (10) accessory switches may be connected to the dimmer. Total blue wire connection wire length may be up to 150 ft (45 m).
- When using an accessory switch in a multi-location installation with a dimmer, the Black and Red wires of all devices are reversible.

WEST OF LOW OF MITTING	\$LUTRON	SPECIFICATION	SUBMITTAL
------------------------	-----------------	---------------	-----------

Job Name:	Model Numbers:
Job Number:	


369987k 27 01.25.23

Wiring Diagrams - Dimmers (continued)

Installation With Power Interfaces and LED Drivers - Neutral Required

Option 1: PHPM¹

PD-10NXD or PD-5NE



¹ See Lutron P/Ns 369356 and 369355 for additional wiring diagrams.

LUTRON SPECIFICATION SUBMITTAL


Job Name:	Model Numbers:
Job Number:	

369987k 28 01.25.23

Wiring Diagrams - Dimmers (continued)


Installation With Power Interfaces and LED Drivers - Neutral Required (continued)

Option 2: GRX-TVI¹ PD-10NXD or PD-5NE



Option 3: Hi-lume 1% 2-wire LED Drivers

PD-10NXD or PD-5NE



Note: For more information on Hi-lume 1% 2-wire LED drivers, see www.lutron.com

LUTRON SPECIFICATION SUBMITTAL

Job Name:	Model Numbers:
Job Number:	

¹ See Lutron P/N 369247 for additional wiring diagrams.


² Blue wire is only present on the PD-10NXD model.

369987k 29 01.25.23

Wiring Diagrams - Fan Controls


Single Pole Installation (load is controlled from 1 location)

PD-FSQN



3-Way Installation (load is controlled from 2 locations)

Option 1: With Pico remote controls
PJ2-2B-xx and wallbox mounting adapters (PICO-WBX-ADAPT)



LUTRON SPECIFICATION SUBMITTAL


Job Name:	Model Numbers:
Job Number:	

The mechanical switch will need to be removed so the Pico remote control can be installed.

369987k 30 01.25.23

Colors and Finishes

Gloss Finishes¹



Due to printing limitations, colors and finishes shown cannot be guaranteed to perfectly match actual product colors.

- ¹ DVRF- models initially available in WH only.
- ² Only available for DVRF-5NS, DVRF-6L, and DVRF-AS.

The Lutron logo, Lutron, Caséta, Diva, Pico, Clear Connect, Claro, Hi-lume, FASS, Radio Powr Savr, and Tu-Wire are trademarks or registered trademarks of Lutron Electronics Co., Inc. in the US and/or other countries.

All product names, logos, and brands are property of their respective owners.

LUTRON SPECIFICATION SUBMITTAL

Job Name:	Model Numbers:
Job Number:	